



Project: Greenacres Elementary School	Date: 01-24-20
Address: 41 Huntington Ave, Scarsdale, NY 10583	Job ID / MU #:
Client: Scarsdale UFSD	Weather: Clear~40deg F

Inspection Type: Noise and Dust Monitoring	Contractor: Park East Construction
Present At Site: Don Herlihy	Sub-Contractor:
General Area: Existing School	CM/Designer:
Specific Location: North and South side of School in the basement, 1st and 2nd Floor	
Last Inspection:	Building Code Section:
Reviewed Approved	Drawings:
	Submittals
	Other:

Deficiency:	Resolution:

Request For Information:					
Non-Conformance Report:					
RFI # : <input type="checkbox"/> Issued	RFI # : <input type="checkbox"/> Answered	NCR # : <input type="checkbox"/> Issued	NCR # : <input type="checkbox"/> Resolved	NCR # : <input type="checkbox"/> Open	

Observations/Notes:
<p>On site for the on going monitoring of construction Noise and Dust for Greenacres Elementary School.</p> <p>Noise Monitoring- Readings were taken in the Library (meter 1) and basement hallway between music and art rooms(meter 2). Average reading was 60.35 dBa in the library. Average reading was 46 and 48dBa in the basement. High levels observed in meter 1 and 2 were local noise from students passing through the hallway, class in library and music being played. No observations of construction noise was noticed during rounds.</p> <p>Dust Monitoring- Readings taken are as show on page 2 of this report.</p> <p>Work performed today- Masonry CMU, Steel erection, Scaffold Erection, chopping and excavation by vacant corridor to school.</p>
Attachments /Photos :
Time on site: 7a Time off site: 330p

Inspected Work Satisfactory (Except As Noted): ☒ No: ☐ Re-inspection Required: ☐ Work Completed: ☒

Inspector: **Sean Donnelly** Signature:  Certification: _____



375 RABRO DRIVE, HAUPPAUGE NY 11788
• TEL: (631) 761-5555 • www.mtllab.net
NYC DoB Special Inspection Agency #0230

REPORT #
SD12420

PHOTOS TAKEN

INSPECTION REPORT

Page 2 of 6

Date	Time	Location	Sample	2.5 microns	10 microns	Temp	RH%
01-24	730a	1st Floor Gym Corridor West	1	9	14	66.0	45.5
	735a	1st Floor Gym Corridor East	2	8	13	66.2	48.2
	740a	1st Floor South Side Corridor	3	12	18	67.3	44.2
	745a	2nd Floor	4	4	9	68.4	46.7
	750a	Basement	5	11	17	69.8	40.0
	850p	1st Floor Gym Corridor	6	7	12	77.5	33.8
	855a	2nd floor	7	8	13	75.2	39.7
	900a	1st Floor South	8	7	11	75.0	39.6
	915a	Basement	9	7	12	75.2	39.0
	1045a	Basement	10	13	22	60.1	43.6
	1050a	1st Floor Gym Corridor	11	11	18	62.6	48.8
	1055a	2nd Floor	12	7	13	67.6	42.5
	1145a	Basement	13	7	15	77.4	35.7
	1150a	1st Floor Gym Corridor	14	7	13	75.6	41.1
	1155a	2nd Floor	15	7	11	75.2	41.6
	1245p	Basement	16	7	13	76.6	38.7
	1250p	1st Floor Gym Corridor	17	6	12	75.6	49.5
	1255p	2nd Floor	18	8	13	74.2	44.3

NOTICE

The field representative is on site solely to observe operation of the contractor identified, for the work identified and it's conformance to the contract documents, and report those operations to the client. The presece and activities of the field representative do not relieve the contractor's obligation to meet the contractual requirements. Th contractor retains sole responsibility for site safety and means/methods of construction seuces. The field representative is not responsible for identifying errors and omissions in the contract documents.




PHOTOS TAKEN

Page 3 of 5

NOTICE

The field representative is on site solely to observe operation of the contractor identified, for the work identified and it's conformance to the contract documents, and report those operations to the client. The presece and activities of the field representative do not relieve the contractor's obligation to meet the contractual requirements. Th contractor retains sole responsibility for site safety and means/methods of construction seuces. The field representative is not responsible for identifying errors and omissions in the contract documents.


Standard Sound Level Meter RealTime Graph
Time: 2020-1-24 14:48:27



Start Time: 24-01-2020,9:13:20
Maxnum: 74.90 24-01-2020,9:49:23
Minnum: 55.90 24-01-2020,9:14:11
Sample Rate: 1.00
Average: 57.69

Meter 1
Library

Standard Sound Level Meter RealTime Graph
Time: 2020-1-24 14:34:19



Start Time: 24-01-2020,7:30:29
Maxnum: 92.70 24-01-2020,12:42:27
Minnum: 41.90 24-01-2020,10:12:46
Sample Rate: 1.00
Average: 50.45

Meter 2 outside artroom